



**NOTES:**

1. WATER METER FURNISHED AND INSTALLED BY ERIE COUNTY WATER AUTHORITY.
2. PRECAST CONCRETE VAULT SHALL BE 4,000 PSI MIX AND SHALL BE A MINIMUM 4 FT X 4 FT X 7 FT SIZE.
3. INSTALL BYPASS AROUND METER IF DIRECTED BY ECWA FORCES.
4. NO PLUMBING CONNECTIONS ALLOWED WITHIN 8" OF VAULT WALL.
5. A HOT-BOX LOCATED ABOVE GRADE IS ALSO ACCEPTABLE.

**SECTION**

N.T.S.

I:\PUBLIC\ENGINEERING\CURRENT ECWA DETAILS\SD22\_WMETER\_VAULT\_2\_SERV

ERIE COUNTY WATER AUTHORITY BUFFALO, NEW YORK	STANDARD DETAIL CONCRETE WATER METER VAULT 1 1/2-INCH AND 2-INCH METERS	DWG. NO. SD22	
		DATE 4/28/92	REVISED 12/17