

C-6

From: greg@advancedfireandelectronic.com
To: [foij; backflow@ecwa.org](mailto:foij;backflow@ecwa.org)
Subject: [EXTERNAL] Advanced Fire - 318 Pearl Street Buffalo, NY - ALL Backflow Preventer FAIL
Date: Monday, November 6, 2023 2:58:52 PM
Attachments: [Advanced Fire - Backflow Preventer Fail.pdf](#)

This message was sent from outside the organization. Do not open links or attachments unless you recognize the source of this email and know the content is safe.

Connor,

See attached

-

As a courtesy and just as a FYI again, the Fire Line, Fire Line Bypass and the Domestic Back Flow Preventers have ALL failed and are really in operable since 2021 and really need to be replaced – we have advised / quoted the customer with No Response and will leave it in your hands.

Let us know if you need the building owners information, Greg.

Sincerely,

Greg Shepard

Advanced Fire and Electronic Systems NY

GT Fire Protection of NY

1450 Olean Road

South Wales, NY. 14139

GM Low Voltage Division / Engineer / Sales

Office – (716) 777-4124

Cell – (716) 489-6465

Fax – (716) 706-1216

Greg@AdvancedFireandElectronic.com

NYSF Alarm License 12000067418

Ohio State Fire Alarm License FPC17-10030672